

## About this document

This document contains screenshots of software available from Cheresources.com. You can find this title in our online store at:

http://www.cheresources.com/cheplusstore/catalogue.php

Clicking the above link should activate your default browser and launch the site.

We recommend using our search feature to find the title.

If you haven't visited our site before, you can find the main page at:

http://www.cheresources.com

Thanks for visiting our site,

Chris Haslego President Cheresources, Inc.

### © COPYRIGHT, 2005. CHERESOURCES, INC.

1422 Goswick Ridge Road Midlothian VA 23114 Fax: 561-658-6489 Email: support@cheresources.com

Content Based Chemical Engineering

### CONTROL VALVES - find flow, pressures known

- BASIS: Control Valve Key Equations, ISA-75.01-1985 (R1995) formerly ISA-S75.01-1985 (R1995)
- **NOTE:** Always begin a new case by retrieving the original file. Direct entry of data in cells that originally contain table lookups could cause functions to be lost, or incorrect calculations. I format cells requiring entry colored **RED**; calculated values are black.
- 1.) Select the appropriate worksheet for the calculation needed.
- 2.) Enter instrument (control valve) identification at [C4].
- 3.) Enter fluid by using [=], then going to fluid name in the gas or liquid tables, and double-clicking the mouse or high-lighting and hitting ther [return key]. Fluid specifics will be returned via lookup tables. For fluids NOT in my tables enter values in the appropriate cells.
- 4.) Enter Cv values as appropriate for Process Safety Calculations these values should be the 100% open value as found in the control valve specification or from the vendors literature.

# Print out using direct Excel commands. This application is provided by Chemical Engineers Resource Website, visit cheresources.com for additional selections.

Print out using direct EXCEL commands.

### 

The originator of these spreadsheet(s) specifically excludes all warranties, expressed or implied, as to the accuracy of the data and other information set forth and assumes NO liability for any losses or damage resulting from the use of the materials or application of the data.

Consistent with GOOD ENGINEERING PRACTICE, the burden rests with the USER of these spreadsheets to review ALL calculations, and assumptions. The USER IS FULLY RESPONSIBLE for the results or decisions based on calculations.

This Spreadsheet Requires MACROS to be ENABLED to ASSURE proper operation. See the Workbook Help Sheet for Additional Instructions on Use.

dmcoffman@aol.com

### 04/11/04

ISA - Control Valve - Compressible Fluid; Flow of Gas or Vapor

VALVE : 1-1/4" FCV VALVE TYPE : Ball / Standard Port (dia app 0.8d) - Either FLUID : **STEAM**  $C_V =$ 47 Mw = 18.02mol. weight valve ID = 1.250k = 1.314451in  $v1 = 11.996933 \text{ ft}^3/\text{lb}$ pipe ID = 2.000in P1 - in =  $P1_a =$ 20 34.7 psia psig P2 - out = 16.5P2<sub>a</sub> = 31.2 psia psig temp. = 258.25991 °F  $T1_a = 718.3$ °R Z = 1.000  $\Delta P =$ 3.5 psi  $W = 19.3 \cdot F_{p} \cdot C_{v} \cdot P1_{a} \cdot Y \cdot (\Delta P/P1_{a} \cdot Mw / T1_{a} \cdot Z)^{0.5}$ ··· Determine Fp ···  $Fp = [(\Sigma K \cdot C_V^2 / 890 \cdot d^4) + 1]^{-1/2}$  reducer,  $K_1 =$ 0.424 increaser,  $K_2 =$ 0.371  $\Sigma K = 0.795$ Fp = 0.904··· Determine Y ···  $Y = 1 - x/(3 * F_{k} * x_{T} ... or... x_{T})$  $x_t = 0.1500$ Y = 0.737955XTP= 0.1367

 $\cdots \quad \text{Calculation} \ \cdots \\$ 

W = 19.3 
$$\cdot$$
 F<sub>p</sub>  $\cdot$  C<sub>v</sub>  $\cdot$  P1<sub>a</sub>  $\cdot$  Y  $\cdot$  ( $\Delta$ P/P1<sub>a</sub>  $\cdot$  Mw / T1<sub>a</sub>  $\cdot$  Z)<sup>0.5</sup>

W = 1056 lb/hr of steam

### 04/11/04

ISA - Control Valve - Compressible Fluid; Flow of Gas or Vapor

VALVE : 32-mm FCV VALVE TYPE : Ball / Standard Port (dia app 0.8d) - Either FLUID : **STEAM**  $C_V =$ 47 Mw = 18.02mol. weight valve ID = 31.75k = 1.3 mm  $v1 = 0.7490489 \text{ m}^3/\text{kg}$ pipe ID = 50.8mm P1 - in = 1.378952 barG  $P1_a = 2.378952$  barA P2 - out = 1.137635 barG  $P2_a = 2.137635$  barA temp. = 125.69499 °C  $T1_a = 398.8$ °K  $\Delta P = 0.241317$  bar Z = 1.000 $W = 94.8 \cdot F_{p} \cdot C_{v} \cdot P1_{a} \cdot Y \cdot (\Delta P/P1_{a} \cdot Mw / T1_{a} \cdot Z)^{0.5}$ ··· Determine Fp ···  $Fp = [(\Sigma K \cdot C_V^2 / 0.00214 \cdot d^4) + 1]^{-1/2} feducer, K_1 =$ 0.424 increaser,  $K_2 =$ 0.371  $\Sigma K = 0.795$ Fp = 0.904

··· Determine Y ···

 $Y = 1 - x/(3 * F_{k} * x_{T} ...or..x_{TF}) \qquad x_{T} = 0.1500$  $Y = 0.733732 \qquad x_{T} = 0.1368$ 

··· Calculation ···

 $W = 94.8 \cdot F_{p} \cdot C_{v} \cdot P1_{a} \cdot Y \cdot (\Delta P/P1_{a} \cdot Mw / T1_{a} \cdot Z)^{0.5}$ 

W = 476 kg/hr of steam

ISA - Control Valve - Incompressible Fluid; Flow of Nonvaporizing Liquid

	VALVE : VALVE TYPE : FLUID : V	FV-5501; Globe Sing WATER	DEAERA gle Port ,	TOR FEEDWAT / Characterized	ER Cage -	Open	
	valve ID =	1.250	in		C <sub>V</sub> =	20	
	pipe ID =	2.000	in		γ <sub>1</sub> =	57.42073	lb/ft <sup>3</sup>
	P1 - in =	20	psig		$P1_a =$	34.7	psia
	P2 - out =	16.5	psig		$P2_a =$	31.2	psia
	$\Delta P =$	3.5	psi		ν =	0.2008491	centistokes
				terr	np. =	298	°F
	Determine Fp						
$Fp = [(\Sigma K \cdot C_v^2 / 890 \cdot d^4) + 1]^{-1/2}$ reducer, $K_1 = 0.424$							0.424
					incre	easer, K <sub>2</sub> =	0.371
	Fp =	0.436163	3			$\Sigma K =$	0.795

 $\cdots \quad \text{Determine } \text{Re}_{v_{,}} \text{ } \text{F}_{r^{,}} \text{ } \text{ } \text{ } \text{q}_{t} \ \cdots \\$ 

$F_d =$	1.00	$\text{Re}_{V} =$	819,884
$F_L =$	0.90	F <sub>r</sub> =	1.00
		q <sub>t</sub> =	39.01

 $\cdots \text{ Predicted Flow Rate } \cdots \qquad W = F_r \cdot q_t$ 

W = 39.005151 gpm

ISA - Control Valve - Incompressible Fluid; Flow of Nonvaporizing Liquid

VALVE : FV-5501; DEAERATOR FEEDWATER VALVE TYPE : Globe Single Port / Characterized Cage - Open FLUID : WATER  $C_V =$ 20 valve ID = 31.75mm  $\gamma_1 = 920.204 \text{ kg/m}^3$ pipe ID = 50.8mm P1<sub>a</sub> = 2.378952 barA P1 - in = 1.378952 barG  $P2_a = 2.137635$  barA P2 - out = 1.137635 barG  $\Delta P = 0.241317$  bar v = 0.2008491 centistokes temp. = 147.77778 °C °F temp. = 298 ··· Determine Fp ···  $F_p = [(\Sigma K \cdot C_v^2 / 0.00214 \cdot d^4) + 1]^{-1/2}$  reducer,  $K_1 =$ 0.424 increaser,  $K_2 = 0.371$ Fp = 0.4362093 $\Sigma K = 0.795$  $\cdots$  Determine Re<sub>V</sub>, F<sub>r</sub>, & q<sub>t</sub>  $\cdots$  $F_d =$  $Re_{V} = 819,779$ 1.00 F1 =  $F_r =$ 0.90 1.00 qt = 39.00

 $\cdots \text{ Predicted Flow Rate } \cdots \qquad W = F_r \cdot q_t \cdot 0.227$ 

 $W = 8.85 \text{ m}^3/\text{hr}$ 

ISA - Control Valve - Incompressible Fluid; Choked Flow of Vaporizing Liquid VALVE : PCV-950008; DESUPERHEAT SPRAY FROM FEEDWATER VALVE TYPE : Angle / Characterized Cage - Close FLUID : Water  $C_{V} = 90$ valve ID = 4.000in  $G_{f} = 0.998$ pipe ID = 6.000in sp. wt.  $P1_a = 214.7$ P1 - in = 200 psig psia  $P2_a = 138.7$ P2 - out = 124 psig psia temp. = 70  $\Delta P =$ 76 psi °F ··· Determine F<sub>LP</sub> ···  $F_L = 0.80$  inlet reducer,  $K_i = 0.401$  $F_{LP} = F_{L} \cdot [(K_{1} \cdot F_{L}^{2} \cdot C_{V}^{2} / 890 \cdot d^{4}) + 1]^{-1/2}$  $F_{LP} = 0.3963814$  $\cdots$  Determine Re<sub>v</sub>, F<sub>r</sub>, & q<sub>t</sub>  $\cdots$  $p_V =$ 0.36 psia  $p_{\rm C} = 3198.72$  $F_{F} = 0.96$  $p_{VC} = 0.344107$ ... Predicted Flow Rate ...  $q_{max} = 1.00 \cdot F_{LP} \cdot C_{v} \cdot [(p_1 - p_{vc}) / G_f]^{0.5}$ 

$$q_{max} = 522.8272$$
 gpm

ISA - Control Valve - Incompressible Fluid; Choked Flow of Vaporizing Liquid VALVE : PCV-950008; DESUPERHEAT SPRAY FROM FEEDWATER VALVE TYPE : Angle / Characterized Cage - Close FLUID : Water  $C_{V} = 90$ valve ID = 101.600 mm  $G_{f} = 0.998$ pipe ID = 152.400 mm sp. wt. P1<sub>a</sub> = P1 - in = 13.7931 barG 14.8 barA P2<sub>a</sub> = P2 - out = 8.55172 barG 9.6 barA  $\Delta P = 5.24138$  barG temp. = 21.11 °C ··· Determine F<sub>LP</sub> ··· F<sub>L</sub> = 0.80 inlet reducer,  $K_i = 0.401$  $F_{IP} = F_{I} \cdot [(K_{i} \cdot F_{I}^{2} \cdot C_{V}^{2} / 0.00214 \cdot d^{4}) + 1]^{-1/2}$  $F_{LP} = 0.3963843$  $\cdots$  Determine Re<sub>v</sub>, F<sub>r</sub>, & q<sub>t</sub>  $\cdots$  $p_V =$ 18.59 mmHg  $p_{c} = 3198.72$  $F_{F} = 0.96$  $p_{VC} = 0.344083$  $\cdots \text{ Predicted Flow Rate } \cdots \qquad q_{max} = 0.865 \cdot F_{LP} \cdot C_{v} \cdot \left[\left(p_{1} - p_{vc}\right) / G_{f}\right]^{0.5}$ 

 $q_{max} = 117.4703 \text{ m}^3/\text{hr}$