

· · NFPA 68 Standard on Explosion Protection by Deflagration Venting - 2013 Edition · ·

1.	Service:	Dust Handling - Collection	Project No:	BR-549	Date:	3/12/2014
2.	Client:	Confidential	Equipment:	Building 45 Baghouse		
· · Equipment / System Specifics · ·						
3.	Dust:	Paper Dust				
		Metric	Unit	Imperial	Unit	Reference
4.	P _{red} :	3.522	bar-g	51.06	psig	Maximum pressure developed during a vented deflagration
5.	P _{stat} :	0.250	bar-g	3.63	psig	Pressure that activates a vent closure
6.	P _{max} :	8.000	bar-g	116.00	psig	Maximum pressure developed in a contained deflagration
7.	V:	25.00	m ³	882.77	cu ft	Volume of equipment being analyzed
8.	L/D Ratio:	4.00				Ratio of height -to- diameter
9.	K _{st} :	200	bar-m/sec			Deflagration index of a dust cloud
8.2.2 - Venting by Means of Low-Inertia Vent Enclosures for Enclosures L/D ≤ 2.0						
10.	A _{v0} =	0.3133	m ²	3.37	sq feet	$A_{v0} = 1 \cdot 10^{-4} \cdot (1 + 1.54 \cdot P_{stat}^{4/3}) \cdot K_{st} \cdot V^{3/4} [(P_{max}/P_{red}) - 1]^{0.5}$
8.2.3 - Elongated Enclosure Area, L/D > 2 & L/D ≤ 6, ... if L/D ≤ 2.0 Eq. 8.2.2 result is shown						
11.	A _{v1} =	0.3133	m ²	3.37	sq feet	$A_{v1} = A_{v0} \cdot [1 + 0.6 \cdot (L/D - 2)^{0.75} \cdot \exp(-0.95 \cdot P_{red}^2)]$
8.2.5 - High Turbulence Correction, if velocity is > 20-m/sec						
12.	Q _{air} =	0.118	m ³ /sec	14,998	SCFH	Air flow rate through the equipment
13.	L _{equip} =	3.64	meter	11.94	feet	Equipment overall length in direction of air product flow
14.	v _{tan_max} =	0.00	m/sec	0.00	feet/sec	Maximum tangential air velocity in the equipment
15.	v _{tan} =	0	m/sec	0.00	feet/sec	Circumferential (tangential) air velocity in the equipment
16.	v _{axial} =	0.01717608	m/sec	0.06	feet/sec	$v_{axial} = (Q_{air} \cdot L) / V$
17.	A _{v2} =	0.3133	m ²	3.37	sq feet	$A_{v2} = [(1 + \max(v_{axial}, v_{tan}) - 20) / 36] \cdot 0.7 \cdot A_{v1}$
8.2.6 - Effects of Panel Inertia, if panel mass ≤ 40-kg/m²						
18.	F _{sh} =	1.1				1.0 for translating panels or 1.1 for hinged panels
18.	n =	1	no. vents	M = 12.20	kg/m ²	2.50 lb/sq ft
19.	M _T =	93.7778	kg/m ²	19.20	lb/ft ²	$M_T = [6.67 \cdot (P_{red}^{0.2}) \cdot (n^{0.3}) \cdot (V/K_{st}^{0.5})]^{1.67}$
20.	A _{v3} =	0.3133	m ²	3.37	sq feet	$A_{v3} = F_{sh} \cdot [1 + (0.0075) \cdot M^{0.6} \cdot K_{st}^{0.5} / (n^{0.3} \cdot V \cdot P_{red}^{0.2})] \cdot A_{v2}$
8.3.1 - Effects of Partial Volume Correction, if X_r can be determined						
21.	Π =	0.440196768	P _{red} /P _{max}	X _r = 1.000		fill fraction > Π
22.	A _{v4} =	0.3133	m ²	3.3726	sq feet	$A_{v4} = A_{v3} \cdot X_r^{-1/3} \cdot (X_r - \Pi / (1 - \Pi))^{0.5}$
8.4.1 - Effects of Initially Elevated Pressure						
23.	P _{initial} =	0	bar-g	0.00	psig	P _{effective} = 0 bar-g
24.	P _{max} ^E =	8.00	bar-g	Π _{effective} = 0.440196768		bar-g
25.	A _{vep} =	10.17369092	m ²	109.51	sq feet	$A_{vep} = A_{v1} \cdot [1 + 1.54 \cdot (P_{stat} - P_{initial} / (1 + P_{effective}))^{4/3}] \cdot (1 / \Pi_{effective} - 1)^{0.5} / [1 + 1.54 \cdot P_{stat}^{4/3} \cdot (P_{max} / P_{red} - 1)^{0.5}]$
8.5.1 - Effects of Vent Ducts						
26.	L _{duct} =	12.00	meter	39.37	feet	ε = 0.26 effective roughness, mm
27.	D _h =	1.5	meter	4.92	feet	f _D = 0.0133 f _D = [1 / (1.14 - 2 log ₁₀ (ε/D _h))]²
28.	K _{inlet} :	1.5	K _{exit} :	0.75	E ₁ = 0.85	E ₁ = (A _{vf} · L _{duct}) / V
29.	K _{ells + add'l K} :	2.4	ΣK =	4.757	E ₂ = 6.37	E ₂ = (10 ⁴ A _{vf}) / (1 + 1.54 P _{stat} ^{4/3}) K _{st} V ^{3/4}
30.	f _D · L/D _h =	0.107	assum A _{vent} =	1.77	meter ²	19.05 sq feet %error = 0.00%
31.	A _{vf} =	1.7700	m ²	19.0523	sq feet	$A_{vf} = A_{v4} \cdot (1 + 1.18 \cdot E_1^{0.8} \cdot E_2^{0.4}) \cdot (K/K_0)^{0.5}$

· · NFPA 68 Standard on Explosion Protection by Deflagration Venting - 2013 Edition · ·

1.	Service:	Dust Handling - Collection			Project No:	BR-549	Date:	3/12/2014
2.	Client:	Confidential			Equipment:	Building 45 Baghouse		
6.3.5.2 - Enclosure Support Criteria $F_r = a \cdot DLF \cdot A_v \cdot P_{red}$								
3.	Dust:	Paper Dust						
		Metric	Unit	Imperial	Unit	Reference		
4.	a :	100		1.00		Units Conversion		
5.	DLF:	1.2	X_m/X_s			Maximum dynamic deflection/static deflection		
6.	$A_v =$	1.00	sq meter	1550.00	sq in	Vent Area		
7.	P_{red} :	3.522	bar-g	51.06	psig	Maximum pressure developed during a vented deflagration		
8.	F_r :	422.59	kN	95002.93	lbf	Maximum reaction force resulting from combustion venting		
6.3.5.5 - Reaction Force Duration $t_f = b \cdot (P_{max}/P_{red})^{0.5} \cdot (V/A_v)$								
		Metric	Unit	Imperial	Unit	Reference		
9.	b :	0.0043		0.0013		Units Conversion		
10.	P_{max} :	8.00	bar-g	116.00	psig	Maximum pressure developed in an unvented explosion		
11.	P_{red} :	1.00	bar-g	14.50	psig	Maximum pressure developed during venting		
12.	V :	24.00	cubic meter	348.00	cubic ft	Enclosure volume		
13.	$A_v =$	3.00	sq meter	32.29	sq ft	Vent Area		
14.	t_f :	0.097	seconds			Duration of Pressure Pulse After Vent Opening		
6.3.5.6 - Enclosure Support Criteria $I = 0.52 \cdot F_r \cdot t_f$								
		Metric	Unit	Imperial	Unit	Reference		
15.	F_r :	423.0	kN	95095.69	lbf	Maximum reaction force resulting from combustion venting		
16.	t_f :	0.100	seconds			Duration of Pressure Pulse After Vent Opening		
17.	I :	22.00	kN-s	4944.98	lbf-s	Total impulse experienced by supporting structure		