



### **About this document**

This document contains screenshots of software available from Cheresources.com. You can find this title in our online store at:

<http://www.cheresources.com/cheplusstore/catalogue.php>

Clicking the above link should activate your default browser and launch the site.

We recommend using our search feature to find the title.

If you haven't visited our site before, you can find the main page at:

<http://www.cheresources.com>

Thanks for visiting our site,

Chris Haslego  
President  
Cheresources, Inc.

**© COPYRIGHT, 2005. CHERESOURCES, INC.**

1422 Goswick Ridge Road  
Midlothian VA 23114

Fax: 561-658-6489  
Email: [support@cheresources.com](mailto:support@cheresources.com)

**Content Based  
Chemical Engineering**

COMPRESSIBLE (GAS / VAPORS) ORIFICE, Calculations
---

**REFERENCES:** MARKS' MECHANICAL ENGINEERS HANDBOOK; PERRY'S CHEMICAL ENGINEERS HANDBOOK; FLUID FLOW by Sabersky & Acosta. Critical pressure ratios and lambda are based on perfect gas. The 'k' value for steam is at average of inlet and outlet pressures.

**NOTE:** Always begin a new case by retrieving the original file. Direct entry of data in cells that originally contain table lookups could cause functions to be lost, or incorrect calculations. I format cells requiring entry colored **RED**; calculated values are black.

.... Find Flow Imperial & Metric ....

- 1.) Enter identification at [C4].
- 2.) Enter fluid at [C6], use [=], then go to the fluid name in the table located below the worksheet at (A46..D106) eg. [=A48] is AIR. k, and MW will automatically be looked up in the table if the fluid is listed. If not enter these at [F7] and [F8].
- 3.) Enter temperature at [C8].
- 4.) Enter inlet pressure at [C33].
- 5.) Enter outlet pressure at [C34].
- 6.) Enter orifice diameter at [C35].
- 7.) Enter the orifice Ko at [C36].

Calculated flow 'W' is indicated at H40 (Imperial) & G42 (Metric).

.... Find Area Imperial & Metric ....

- 1.) Enter identification at [C4].
  - 2.) Enter fluid at [C6], use [=], then go to the fluid name in the table located below the worksheet at (A37..D97) eg. [=A39] is AIR. k, and MW will automatically be looked up in the table if the fluid is listed. If not enter these at [C9] and [G8].
  - 3.) Enter flow 'W' at [C8].
  - 4.) Enter orifice coefficient 'Ko' at [G9].
  - 5.) Enter inlet temperature 'T1' at [C10].
  - 6.) Enter inlet pressure 'P1' at [C11].
  - 7.) Enter outlet pressure 'P2' at [C12].
- Area 'A' (sq in) is calculated and shown at [E21].  
Diameter 'D' (in) is calculated and shown at [G30].

**NOTE:** When using this program to find the required area of a rupture disk, the flow coefficient 'Ko' must be 0.62, and the back pressure 'P2' must not exceed 10% of the MAP.

.... Flow 2 Orifices Imperial & Metric ....

- 1.) Enter identification at [C4].
- 2.) Enter fluid at [C6], use [=], then go to the fluid name in the table located below the worksheet at (A53..D113) eg. [=A55] is AIR. k, and MW will automatically be looked up in the table if the fluid is listed. If not enter these at [C7] and [F7].
- 3.) Enter temperature at [C8].
- 4.) Enter inlet pressure 'P1' at [F24].
- 5.) Enter outlet pressure 'P3' at [H30].
- 6.) Enter Ko for first orifice at [F33].
- 7.) Enter first orifice diameter at [F34].
- 8.) Enter Ko for second orifice at [H33].
- 9.) Enter second orifice diameter at [H34].

**NOTE:!** The calculation **REQUIRES** the pressures to ascend from P1 to P2 to P3; this may require a manual random number entry of P1 or P3 to iterate P2 to within the desired range. Depress the Calculate button to converge the equation.

Calculated flow 'W' is indicated at F44.

.... Flow Orifice/Control Valve Imperial & Metric ....

- 1.) Enter identification at [C4].
- 2.) Enter fluid at [C6], use [=], then go to the fluid name in the table located below the worksheet at (A55..D115) eg. [=A57] is AIR. k, and MW will automatically be looked up in the table if the fluid is listed. If not enter these at [C7] and [F7].
- 3.) Enter temperature at [C8].
- 4.) Enter inlet pressure 'P1' at [F24].
- 5.) Enter outlet pressure 'P3' at [H30].
- 6.) Enter Ko for first orifice at [F33].
- 7.) Enter first orifice diameter at [F34].
- 8.) Enter the Control Valve Cv at [H33].

**NOTE:!** The calculation **REQUIRES** the pressures to ascend from P1 to P2 to P3; this may require a manual random number entry of P1 or P3 to iterate P2 to within the desired range. Depress the Calculate button to converge the equation.

Calculated flow 'W' is indicated at C46 or F46 dependant upon reaching critical flow conditions.

.... Flow thru Perforated Screen Imperial & Metric ....

**REFERENCES:** INDUSTRIAL PERFORATORS ASSOCIATION; TESTING BY BOYLE ENGINEERING LABORATORIES and MARKS' MECHANICAL ENGINEERS HANDBOOK

**BACKGROUND:** In many applications of perforated plate the estimated energy loss or pressure loss through perforated plates is one of the design considerations. This spreadsheet was developed based upon loss information from a battery of tests conducted on a laboratory air flow system at Boyle Engineering. This system maintained a non-swirling flow impacting perpendicularly on the sample. Various perforated thin gage plates were inserted into a uniform velocity air flow stream. Pressure loss for ambient air flow was then measured at a series of velocities for each flow. This data therefore presents the best flow condition value of loss. In applying this data consideration must be given to the actual anticipated characteristics of the flow impacting on the perforated plate. Distorted flow patterns with high velocity zones will increase the loss of the plate, as will directional flow not perpendicular to the plat surface.

- 1.) Enter the service condition at [C4].
- 2.) Enter the fluid at [G6], use '=' and scroll the fluid database, eg. AIR is (=A48).
- 3.) Enter the supply pipe id [C6], this assists in determining the velocity.
- 4.) Enter (W) the calculated mass flow thru the supply pipe at [C7].
- 5.) The impact velocity is calculated and shown at [C8].
- 6.) Enter the fluid temperature at [C9].
- 7.) Enter the upstream pressure at [C10].
- 8.) Enter the downstream pressure at [C11].
- 9.) Enter the per cent "open area" of the perforated plate at [C12].
- 10.) The specific gravity and molecular weight will be looked up and inserted in cells G7 & G8, if in the database If not enter directly.
- 11.) The appropriate equation is selected from the % open area and shown at [C16].

The delta P is calculated and shown at [C18] and [C20].

**Print out using direct Excel commands. This application is provided by Chemical Engineers Resource Website, visi [cheresources.com](http://cheresources.com) for additional selections.**

**Print out using direct EXCEL commands.**

<<<<<<< Psafety © January 2001, by Don Coffman >>>>>>>

The originator of these spreadsheet(s) specifically excludes all warranties, expressed or implied, as to the accuracy of the data and other information set forth and assumes NO liability for any losses or damage resulting from the use of the materials or application of the data.

Consistent with GOOD ENGINEERING PRACTICE, the burden rests with the USER of these spreadsheets to review ALL calculations, and assumptions. The USER IS FULLY RESPONSIBLE for the results or decisions based on calculations.

This Spreadsheet Requires MACROS to be ENABLED to ASSURE proper operation. See the Workbook Help Sheet for Additional Instructions on Use.

dmcoffman@aol.com

## Compressible Flow Thru Orifice, Find Flow

**SERVICE:** BACK-SOLVE To Find Design Flow Coefficient to Match Honeywell

fluid: **AIR**

$$k = 1.41$$

$$T1 = 70 \text{ } ^\circ\text{F}$$

$$MW = 28.97 \text{ mol. weight}$$

$$T1_a = 529.6 \text{ } ^\circ\text{R}$$

.... critical pressure ratio ....

$$PR_{crit} := \left( \frac{2}{k+1} \right)^{\left( \frac{k}{k-1} \right)}$$

$$PR_{crit} = 0.527$$

.... lambda at critical pressure ratio ....

$$crit_{lambda} := 2415 \cdot \sqrt{\left( \frac{k}{k-1} \right) \cdot PR_{crit}^{\left( \frac{2}{k} \right)} \cdot PR_{crit}^{\left( \frac{k+1}{k} \right)}}$$

$$crit_{lambda} = 1172$$

.... determine lambda ....

$$P1_a = P1 + 14.7$$

$$PR = P2_a / P1_a = 0.986$$

$$lambda := 2415 \cdot \sqrt{\frac{k}{k-1} \cdot \left[ \left( \frac{P2_a}{P1_a} \right)^{\left( \frac{2}{k} \right)} \cdot \left( \frac{P2_a}{P1_a} \right)^{\left( \frac{k+1}{k} \right)} \right]}$$

$$lambda = 282.39$$

.... flow calculation ....

	psig	psia
<b>P<sub>1</sub></b>	0	14.7
<b>P<sub>2</sub></b>	-0.2	14.496
<b>Dia =</b>	0.20	inches
<b>K<sub>o</sub> =</b>	0.60	coefficient

.... determine specific volume ....

$$v_1 := \frac{10.73 \cdot T1_a}{M_w \cdot P1_a}$$

$$v_1 = 13.344 \text{ ft}^3/\text{lb}$$

$$Area := \left( \frac{\pi}{4} \right) \cdot D^2 = 0.031 \text{ in}^2$$

$$W := K_o \cdot A \cdot \lambda \cdot \sqrt{\left( \frac{P1_a}{v_1} \right)} = 6 \text{ lb/hr}$$

## Compressible Flow Thru Orifice, Find Flow

**SERVICE:** BACK-SOLVE To Find Design Flow Coefficient to Match Honeywell

fluid: **STEAM**

k = 1.3

MW = 18.00 mol. weight

T1 = 201.6667 °C

T1<sub>a</sub> = 474.8167 °K

.... critical pressure ratio ....

$$PR_{crit} := \left( \frac{2}{k+1} \right)^{\left( \frac{k}{k-1} \right)}$$

PR<sub>crit</sub> = 0.546

.... lambda at critical pressure ratio ....

$$crit_{lambda} := 2415 \cdot \sqrt{\left( \frac{k}{k-1} \right) \cdot PR_{crit}^{\left( \frac{2}{k} \right)} \cdot PR_{crit}^{\left( \frac{k+1}{k} \right)}}$$

crit<sub>lambda</sub> = 1139

.... determine lambda ....

$$P1_a = P1 + 101325$$

$$PR = P2_a / P1_a = 0.800$$

$$lambda := 2415 \cdot \sqrt{\frac{k}{k-1} \cdot \left[ \left( \frac{P2_a}{P1_a} \right)^{\left( \frac{2}{k} \right)} \cdot \left( \frac{P2_a}{P1_a} \right)^{\left( \frac{k+1}{k} \right)} \right]}$$

lambda = 949.06

.... flow calculation ....

	Pa	Pa
<b>P<sub>1</sub></b>	1516846.6	1618171.6
<b>P<sub>2</sub></b>	1192793	1294118
<b>Dia =</b>	42.16	millimeter
<b>K<sub>o</sub> =</b>	0.70	coefficient

.... determine specific volume ....

$$v_1 := \frac{8314 \cdot T1_a}{M_w \cdot P1_a}$$

$$v_1 = 0.1355 \text{ m}^3/\text{kg}$$

$$Area = \left( \frac{\pi}{4} \right) \cdot D^2 = 0.0013963 \text{ m}^2$$

$$W := 5.88 \cdot K_o \cdot A \cdot \lambda \cdot \sqrt{\frac{P1_a}{v_1}} \cdot 10^{-4} = 1.8924783 \text{ kg/sec}$$

## Compressible Flow Thru Orifice, Find Area

**SERVICE:** Steam Turbine, Determination of Nozzle Diameter

fluid: STEAM

W = 6000 lb/hr  
 k = 1.320  
 T1 = 258.0 °F  
 P1 = 25.00 psig  
 P2 = 15.0 psig

MW = 18.000 mol. weight  
 Ko = 0.60  
 T1a = 717.6 °R  
 P1a = 39.7 psia  
 P2a = 29.7 psia  
 v1 = 10.78 cu ft/lb

lambda, λ: 1026  
 critical λ: 1146  
 PR: 0.7481  
 Prcrit: 0.5421

.... Area ....

$$A := \frac{W}{\left( K_o \cdot \lambda \cdot \sqrt{\frac{P1_a}{v_1}} \right)} = 5.077 \text{ in}^2$$

.... Diameter ....

$$\text{Diameter} := \sqrt{4 \cdot \frac{A}{\pi}} = 2.543 \text{ inch}$$

## Compressible Flow Thru Orifice, Find Area

**SERVICE:** Steam Turbine, Determination of Nozzle Diameter

fluid: STEAM

W = 0.7559873 kg/sec

k = 1.310

T1 = 207.8 °C

P1 = 1723689.3 Pa

P2 = 103421.36 Pa

MW = 18.000 mol. weight

Ko = 0.60

T1a = 480.9278 °K

P1a = 1825014.3 Pa abs

P2a = 204746.4 Pa abs

v1 = 0.121717 cu meter/kg

lambda, λ: 1143

critical λ: 1143

PR: 0.1122

Prcrit: 0.5439

.... Area ....

$$A = \frac{(W \cdot 10^4)}{5.88 \cdot K_o \cdot \lambda \cdot \sqrt{\left(\frac{P1_a}{v_1}\right)}} = 0.00048435 \text{ m}^2$$

.... Diameter ....

$$\text{Diameter} := \sqrt{4 \cdot \frac{A}{\pi}} = 0.0248333 \text{ meter}$$

## Compressible Flow - Two Orifices In Series

### SERVICE: Two Orifices in Series - Prior PTCV to 4M Steam Hood

fluid: **STEAM**  
 k = 1.300                      MW = 18.000    mol. weight  
 T1 = **395**    °F                      T1a = 854.6    °R

.... critical pressure ratio ....

$$PR_{crit} := \left( \frac{2}{k+1} \right)^{\left( \frac{k}{k-1} \right)}$$

$$PR_{crit} = 0.5457$$

.... lambda at critical pressure ratio ....

$$crit_{lambda} := 2415 \cdot \sqrt{\left( \frac{k}{k-1} \right) \cdot PR_{crit}^{\left( \frac{2}{k} \right) - PR_{crit}^{\left( \frac{k+1}{k} \right)}}$$

$$crit_{lambda} = 1139$$

		Orifice #1	Orifice #2
Upstream Pressure, [psig]	P1	220	
Upstream Pressure, [psia]	P1 <sub>a</sub>	234.7	
Upstream Specific Volume, [ft <sup>3</sup> /lb]	v1	2.1705861	
Intermediate Pressure, [psig]	P2		180.56298
Intermediate Pressure, [psia]	P2 <sub>a</sub>		195.26298
Intermediate Spec Vol, [ft <sup>3</sup> /lb]	v2		2.6089767
Downstream Pressure, [psig]	P3		123
Downstream Pressure, [psia]	P3 <sub>a</sub>		137.7
Downstream Spec Vol, [ft <sup>3</sup> /lb]	v3		3.6996119
Orifice Coefficient,	K <sub>o</sub>	0.8	0.8
Orifice Internal Diameter,	inches	0.875	0.875
Orifice Area,	in <sup>2</sup>	0.6013205	0.6013205
Pressure Ratio, (P2 <sub>a</sub> /P1 <sub>a</sub> )	PR	0.8319684	0.7052028
Lambda,	λ	889.67346	1069.3597
Flow Rate W,	lb/hr	4450.3549	4450.355

.... flow calculation ....

error, Δ lb/hr = 0.00%

$$W := K_o \cdot A \cdot \lambda \cdot \sqrt{\left( \frac{P1_a}{V_1} \right)} = 4450.4 \text{ lb/hr of steam}$$

## Compressible Flow - Two Orifices In Series

### SERVICE: Two Orifices in Series - Prior PTCV to 4M Steam Hood

fluid: **STEAM**

k = 1.300

T1 = 201.6667 °C

MW = 18.000 mol. weight

T1a = 474.8167 °K

.... critical pressure ratio ....

$$PR_{crit} := \left( \frac{2}{k+1} \right)^{\left( \frac{k}{k-1} \right)}$$

$$PR_{crit} = 0.5457$$

.... lambda at critical pressure ratio ....

$$crit_{lambda} := 2415 \cdot \sqrt{\left( \frac{k}{k-1} \right)} \cdot PR_{crit}^{\left( \frac{2}{k} \right) - PR_{crit}^{\left( \frac{k+1}{k} \right)}}$$

$$crit_{lambda} = 1139$$

		Orifice #1	Orifice #2
Upstream Pressure, [Pa]	P1	1516846.6	
Upstream Pressure, [Pa] Abs.	P1 <sub>a</sub>	1618171.6	
Upstream Specific Volume, [m <sup>3</sup> /kg]	v1	0.1355311	
Intermediate Pressure, [Pa]	P2		1244939.7
Intermediate Pressure, [Pa] Abs.	P2 <sub>a</sub>		1346264.7
Intermediate Spec Vol, [m <sup>3</sup> /kg]	v2		0.1629045
Downstream Pressure, [Pa]	P3		848055.15
Downstream Pressure, [Pa] Abs.	P3 <sub>a</sub>		949380.15
Downstream Spec Vol, [m <sup>3</sup> /kg]	v3		0.231006
Orifice Coefficient,	K <sub>o</sub>	0.8	0.8
Orifice Internal Diameter,	meter	0.022225	0.022225
Orifice Area,	m <sup>2</sup>	0.0003879	0.0003879
Pressure Ratio, (P2 <sub>a</sub> /P1 <sub>a</sub> )	PR	0.8319666	0.7051957
Lambda,	λ	889.67701	1069.3662
Flow Rate W,	kg/sec	0.561004	0.561004

.... flow calculation ....

error, Δ kg/sec = 0.00%

$$W := 5.88 \cdot K_o \cdot A \cdot \lambda \cdot \sqrt{\frac{P1_a}{v_1}} \cdot 10^{-4} = 0.561004 \text{ kg/sec of steam}$$

## Compressible Flow - Two Flow Restrictions In Series

**SERVICE:** Low-Pressure Steam Flow to #4 Paper Machine Steam Hood

fluid: **STEAM**

k = 1.320

T1 = 302 °F

MW = 18.000 mol. weight

T1a = 761.6 °R

.... critical pressure ratio ....

$$PR_{crit} := \left( \frac{2}{k+1} \right)^{\left( \frac{k}{k-1} \right)}$$

$$PR_{crit} = 0.5421$$

.... lambda at critical pressure ratio ....

$$\text{crit lambda} := 2415 \cdot \sqrt{\left( \frac{k}{k-1} \right)} \cdot PR_{crit}^{\left( \frac{k+1}{k} \right)}$$

$$\text{crit lambda} = 1146$$

		Flow Orifice	Cntrl Valve
Upstream Pressure, [psig]	P1	50	
Upstream Pressure, [psia]	P1 <sub>a</sub>	64.7	
Upstream Specific Volume, [ft <sup>3</sup> /lb]	v1	7.0169741	
Intermediate Pressure, [psig]	P2		45.388754
Intermediate Pressure, [psia]	P2 <sub>a</sub>		60.088754
Intermediate Spec Vol, [ft <sup>3</sup> /lb]	v2		7.5554608
Downstream Pressure, [psig]	P3		16.5
Downstream Pressure, [psia]	P3 <sub>a</sub>		31.2
Downstream Spec Vol, [ft <sup>3</sup> /lb]	v3		14.551225
Orifice Coefficient,	K <sub>o</sub>	0.6	C <sub>v</sub> 23
Orifice Internal Diameter,	inches	1.25	
Orifice Area,	in <sup>2</sup>	1.2271846	
Pressure Ratio, (P2 <sub>a</sub> /P1 <sub>a</sub> )	PR	0.9287288	0.5192319
Lambda,	λ	618.13405	
Flow Rate W,	lb/hr	1382.0413	1382.0413

.... flow calculation ....

· Equation #1 - subcritical

$$W = 1.45 \cdot C_s \cdot (P_1 - P_2)^{0.4425} \cdot P1_a^{0.5575}$$

$$W = 0 \text{ lb/hr}$$

· Equation #2 - critical

$$W = C_s \cdot P1_a$$

$$W = 1382.0413 \text{ lb/hr}$$

error, Δ lb/hr = 0.00%

## Compressible Flow - Two Flow Restrictions In Series

**SERVICE:** Low-Pressure Steam Flow to #4 Paper Machine Steam Hood

fluid: **STEAM**

k = 1.320

T1 = 150 °C

MW = 18.000 mol. weight

T1a = 423.15 °K

.... critical pressure ratio ....

$$PR_{crit} := \left( \frac{2}{k+1} \right)^{\left( \frac{k}{k-1} \right)}$$

$$PR_{crit} = 0.5421$$

.... lambda at critical pressure ratio ....

$$crit \text{ lambda} := 2415 \cdot \sqrt{\left( \frac{k}{k-1} \right)} \cdot PR_{crit}^{\left( \frac{k+1}{k} \right)}$$

$$crit \text{ lambda} = 1146$$

		Flow Orifice	Cntrl Valve
Upstream Pressure, [Pa]	P1	344737.86	
Upstream Pressure, [Pa] Abs.	P1 <sub>a</sub>	446062.86	
Upstream Specific Volume, [m <sup>3</sup> /kg]	v1	0.4381631	
Intermediate Pressure, [Pa]	P2		312892.1
Intermediate Pressure, [Pa] Abs.	P2 <sub>a</sub>		414217.1
Intermediate Spec Vol, [m <sup>3</sup> /kg]	v2		0.4718499
Downstream Pressure, [Pa]	P3		114452.97
Downstream Pressure, [Pa] Abs.	P3 <sub>a</sub>		215777.97
Downstream Spec Vol, [m <sup>3</sup> /kg]	v3		0.9057842
Orifice Coefficient,	K <sub>o</sub>	0.6	C <sub>v</sub>
Orifice Internal Diameter,	meter	0.03175	
Orifice Area,	m <sup>2</sup>	0.0007917	
Pressure Ratio, (P2 <sub>a</sub> /P1 <sub>a</sub> )	PR	0.928607	0.5209297
Lambda,	λ	618.61564	
Flow Rate W,	kg/sec	0.174344	0.174344

.... flow calculation ....

· Equation #1 - subcritical

$$W = 2.65 \cdot C_s \cdot (P_1 - P_2)^{0.4425} \cdot P_{1a}^{0.5575} \cdot 10^{-8}$$

$$W = 0 \text{ kg/sec}$$

· Equation #2 - critical

$$W = 1.83 \cdot C_s \cdot P_{1a} \cdot 10^{-8}$$

$$W = 0.174344 \text{ kg/sec}$$

$$\text{error, } \Delta \text{ kg/sec} = 0.00\%$$

Calculate

Compressible Flow Thru A Perforated Screen - Find $\Delta P$
--

**SERVICE:** Mix Vessel Eq.#2301-12; Flow thru Gooseneck Vent & Bug Screen

.....	Screen	.....	Fluid	.....	
Internal Diameter:	12	inches	fluid:	AIR	
Flow Rate:	50000	W, lb/hr	Specific Gravity:	1.000	
impact velocity:	7182.7	fpm	Mol. Weight:	28.970	
Temperature:	265.0	T1, °F	Temperature, Abs:	724.6	T1a, °R
Upstream Press:	25.00	P1, psig	Pressure, Abs:	39.7	P1a, psia
Downstream Press:	2.0	P2, psig	Pressure, Abs:	16.7	P2a, psia
Open Area:	65	%	Specific Volume:	6.76	v1, cu ft/lb

$$\Delta P = 0.19717 + -5.65E-06 \cdot \text{velocity} + 1.95E-08 \cdot \text{velocity}^2$$

$$\Delta P = 1.163 \text{ in. w.c.}$$

$$\Delta P = 0.042 \text{ psig}$$

Compressible Flow Thru A Perforated Screen - Find $\Delta P$
--

**SERVICE:** Mix Vessel Eq.#2301-12; Flow thru Gooseneck Vent & Bug Screen

Screen	Fluid
Internal Diameter: 304.8 mm	fluid: AIR
Flow Rate: 6.299894 W, kg/sec	Specific Gravity: 1.000
impact velocity: 2185.41 m/min	Mol. Weight: 28.970
Temperature: 129.4 T <sub>1</sub> , °C	Temperature, Abs: 402.5944 T <sub>1a</sub> , °K
Upstream Press: 172368.9 P <sub>1</sub> , Pa	Pressure, Abs: 273721.9 P <sub>1a</sub> , Pa
Downstream Press: 13789.52 P <sub>2</sub> , Pa	Pressure, Abs: 115142.5 P <sub>2a</sub> , Pa
Open Area: 65 %	Specific Volume: 0.42 v <sub>1</sub> , m <sup>3</sup> /kg

$$\Delta P = 0.19717 + -5.65E-06 \cdot \text{velocity} + 1.95E-08 \cdot \text{velocity}^2$$

$$\Delta P = 29.442 \text{ mm H}_2\text{O}$$

$$\Delta P = 0.289 \text{ kPa}$$

										ORIFICE PLATES & FLANGES								
										SPEC NO:						SHT 1 of 8		
										NO	BY	DATE	REVISION	DATE	REV			
										A	DMC	4/12/2002	Purchase	4/12/2002	A	CONTRACT		
										BY	CHK	APPR						
										DMC								
Orifice Plates						Orifice Flanges												
1.	Plate Type :	Sanitary Orifice Plate				7.	Tap Type :	NA										
2.	Concentric :	<input checked="" type="checkbox"/>	Other :			8.	Tap Size :	NA										
3.	Bore:	Maximum Rate :	<input checked="" type="checkbox"/>	Nearest 1/8 in. Drill :		9.	Flange Type :	1-1/2" Sanitary Tri-Clamp										
4.	Material:	304SS :		316SS :	<input checked="" type="checkbox"/>	Other :												
5.	Ring Material & Type	Bonded Silicone (White) Plate Gasket				10.	Material :	316 Stainless Steel										
6.	Mfr. & Model No.	Newman Model A80MP-XW				11.	Flanges :	Included :		By Others :	<input checked="" type="checkbox"/>							
					12.	Rating :												
<b>GENERAL</b>	13.	Tag Number	FO-0526															
	14.	Service	32% Sodium Hydroxide to V-1070															
		P&ID	X-26004.2LO															
	15.	Line Number	1-1/2"-CAUS-001-004															
<b>FLUID DATA</b>	16.	Fluid	32% Sodium Hydroxide															
	17.	Fluid State	Liquid															
	18.	Maximum Flow	4-GPM															
	19.	Normal Flow	2-GPM															
	20.	Pressure (max/norm)	29/11															
	21.	Temp (max/norm)	AMB															
	22.	Specific Gravity @ Base	1.34															
	23.	Operating Specific Gravity	1.34															
	24.	Supercomp. factor	NA															
	25.	Mol. Weight	Cp/Cv															
	26.	Operating Viscosity (cp)	30 CPS															
27.	Quality % or °Superheat	NA																
28.	Base Press.	Base Temp.	68															
29.	Differential Pressure	10.14-PSIG																
<b>METER</b>	30.	Type of Meter	NA															
	31.	Diff. Range - Dry	NA															
	32.	Seal sp. Gr. @ 60°F	NA															
	33.	Static Press. Range	NA															
	34.	Chart or Scale Range	NA															
	35.	Chart Multiplier	NA															
<b>PLATE &amp; FLANGE</b>	36.	Beta = d/D	0.13686															
	37.	Orifice Bore Diameter	0.1875															
	38.	Line Size/Sched/I.D.	1-1/2" / Tube / 0.065 Wall Thk.															
	39.	Flange Rating	1-1/2" Sanitary Tri-Clamp															
	40.	Vent or Drain Hole	NA															
	41.	Plate Thickness	1/16"															
	42.	Manufacturer	Newman Sanitary Gasket Company															
	43.	Model No.	A80MP-XW															
<b>Notes:</b>																		
1.) Electropolish to 50 Ra																		
2.) Permanently Affix SS Tag. Use minimum 3/16" Lettering.																		
3.)																		
4.)																		

Physical Properties				Pipe Data Table			
fluid	form	K	MW	nominal diameter	ID schd 10S	ID schd 40	ID schd 80
ACETIC ACID	CH3COOH	1.15	60.05				
ACETYLENE	C2H2	1.26	26.00	1/2	0.674	0.622	0.546
AIR		1.41	28.97	3/4	0.884	0.824	0.742
AMMONIA	NH3	1.31	17.03	1	1.097	1.049	0.957
ARGON	A	1.67	39.90	1 1/4	1.422	1.380	1.278
BENZENE	C6H6	1.12	78.11	1 1/2	1.682	1.610	1.500
BROMINE	Br2	1.32	159.83	2	2.157	2.067	1.939
BUTANE	C4H10	1.09	58.10	2 1/2	2.635	2.469	2.323
CARBON DIOXIDE	CO2	1.30	44.01	3	3.260	3.068	2.900
CARBON DISULFIDE	CS2	1.21	76.13	3 1/2	3.760	3.548	3.364
CARBON MONOXIDE	CO	1.40	28.01	4	4.260	4.026	3.826
CHLORINE	CL2	1.36	70.91	6	6.357	6.065	5.761
CHLOROFORM	CHCl3	1.15	119.39	8	8.329	7.981	7.625
CYANOGEN	(CN)2	1.26	52.02	10	10.420	10.020	9.562
CYCLOHEXANE	C6H12	1.08	84.16	12	12.390	11.938	11.374
ETHANE	C2H6	1.22	30.00	14	13.624	13.124	12.500
ETHYL ALCOHOL	C2H5OH	1.13	46.07	16	15.624	15.000	14.312
ETHYL CHLORIDE	C2H5CL	1.13	64.50	18	17.624	16.867	16.124
ETHYL ETHER	(C2H5)2O	1.08	74.12	20	19.564	18.812	17.938
ETHYLENE	C2H4	1.26	28.00	24	23.500	22.624	21.562
FREON 11	F-11	1.11	137.40				
FREON 11	F-114a	1.08	170.90				
FREON 12	F-12	1.13	120.90				
FREON 22	F-22	1.16	86.50				
FUEL OIL (#2)		1.11	96.00				
GASOLINE		1.06	86.00				
HELIUM	He	1.66	4.00				
HEPTANE	C7H16	1.05	100.20				
HEXANE	C6H14	1.08	86.17				
HYDROCHLORIC ACID	HCl	1.41	36.47				
HYDROGEN	H2	1.41	2.02				
HYDROGEN BROMIDE	HBr	1.42	80.92				
HYDROGEN CHLORIDE	HCl	1.41	36.47				
HYDROGEN CYANIDE	HCN	1.31	27.03				
HYDROGEN IODIDE	HI	1.40	127.91				
HYDROGEN SULFIDE	H2S	1.32	34.08				
IODINE	I2	1.30	253.84				
ISOBUTANE	C4H10	1.11	58.10				
ISOPENTANE	C5H12	1.08	72.10				
MERCURY	Hg	1.67	200.60				
METHANE	CH4	1.31	16.04				
METHYL ALCOHOL	CH3COOH	1.14	74.08				
METHYL ALCOHOL	CH3OH	1.20	32.04				
METHYL CHLORIDE	CH3Cl	1.20	50.49				
METHYLENE CHLORIDE	(CH2)2O	1.11	46.07				
NATURAL GAS	typical	1.27	19.50				
NEON	Ne	1.64	20.20				
NITRIC OXIDE	NO	1.40	30.01				
NITROGEN	N2	1.40	28.02				
NITROUS OXIDE	N2O	1.30	44.02				
OCTANE	C8H18	1.05	114.22				
OXYGEN	O2	1.40	32.00				
PENTANE	C5H12	1.06	72.10				
PHOSPHORUS	P	1.17	30.97				
POTASSIUM	K	1.77	39.10				
PROPANE	C3H8	1.15	44.10				
PROPENE	C3H6	1.14	42.10				
SODIUM	Na	1.68	22.99				
STEAM	H2O	1.30	18.00				
SULPHUR DIOXIDE	SO2	1.29	64.07				
TOLUENE	C6H5CH3	1.09	92.13				

  

Steam, k	
-15	1.32
50	1.31
150	1.30
300	1.29
600	1.28
10000	1.28