



About this document

This document contains screenshots of software available from Cheresources.com. You can find this title in our online store at:

<http://www.cheresources.com/cheplusstore/catalogue.php>

Clicking the above link should activate your default browser and launch the site.

We recommend using our search feature to find the title.

If you haven't visited our site before, you can find the main page at:

<http://www.cheresources.com>

Thanks for visiting our site,

Chris Haslego
President
Cheresources, Inc.

© COPYRIGHT, 2005. CHERESOURCES, INC.

1422 Goswick Ridge Road
Midlothian VA 23114

Fax: 561-658-6489
Email: support@cheresources.com

***Content Based
Chemical Engineering***

Tank/Vessel Overflow Line Sizing

NOTE: The program has two parts: the first is for sizing the overflow, and second is for calculating the capacity of an overflow.

Always begin a new case by retrieving the original file. Direct entry of data in cells that originally contain table lookups could cause functions to be lost, or incorrect calculations. I format cells requiring entry colored **RED**; calculated values are black.

- 1.) Enter identification at [C4].
- 2.) Enter total liquid inflow at [C7].
- 3.) Enter fluid at [G7], use [=], then go to fluid name in table (A44.... D92) eg. [=A92] is WATER. The Specific Gravity at G8 will be automatically looked up in the table, if the fluid is in table. If not, enter directly in [G8].
- 4.) Enter liquid head (inches) at [C9].
- 5.) Select the pipe schedule "10" or "40" with the drop-down at [F13].
- 6.) The required overflow inside diameter is shown at [F18].
- 7.) The recommended size overflow is given at row 22 and is based on the schedule previously selected. The look-up tables follow schedule 40 pipe through 12 inch and standard (STD) weight above 12 inch.

This latter part of the program is set up to automatically calculate the capacity of the overflow previously chosen. By comparing capacities to the inflow, the area for future inflow increase can be determined.

To use this part separately:

- 8.) Enter identification at [C27].
- 9.) Enter specific gravity at [D29].
- 10.) Enter liquid head (inches) at [D30].
- 11.) Enter overflow ID at [D33], use pipe table if appropriate.

Calculated overflow capacity is indicated at [E38].

Print out using direct Excel commands. This application is provided by Chemical Engineers Resource Website, visit cheresources.com for additional selections.

Print out using direct EXCEL commands.

<<<<<<<< Psafety © January 2001, by Don Coffman >>>>>>>>

The originator of these spreadsheet(s) specifically excludes all warranties, expressed or implied, as to the accuracy of the data and other information set forth and assumes NO liability for any losses or damage resulting from the use of the materials or application of the data.

Consistent with GOOD ENGINEERING PRACTICE, the burden rests with the USER of these spreadsheets to review ALL calculations, and assumptions. The USER IS FULLY RESPONSIBLE for the results or decisions based on calculations.

This Spreadsheet Requires MACROS to be ENABLED to ASSURE proper operation. See the Workbook Help Sheet for Additional Instructions on Use.

dmcoffman@aol.com

Tank/Vessel Overflow Line Sizing

DEVICE : Tank #2501; Overflow Tag: 03000

..... Vessel Fluid
Vessel Inflow: 7000 gpm	Liquid: WATER
W: 3500000 lb/hr	Specific Gravity: 1.000
ΔP : 4 inch	Density: 62.4 lb/cu. ft.
or 0.1443001 psig	Frictional Loss, N: 1.5 (simple overflow)

Select Overflow Pipe Schedule :

$$\text{dia} := \left[(2.79 \cdot 10^{-7}) \cdot N \cdot \frac{W^2}{(\Delta P \cdot D)} \right]^{0.25} = 27.469139 \text{ inch}$$

-- A 30-inch overflow is recommended --

..... **Selected Overflow Capacity**

DEVICE : Tank #2501; Overflow Tag: 03000

sp.gr. = 1.000
 ΔP = 4.000 inch = 0.1443001 psi
D = 1.000 × 62.4 = 62.4 lb/cu.ft.
N = 1.5 (for simple o'flow)
d = 29.376 inch (overflow ID)

$$W := \sqrt{\frac{\Delta P \cdot D \cdot d^4}{N \cdot (2.79 \cdot 10^{-7})}} = 4002794.2 \text{ lb/hr or } 8,005.6 \text{ gpm}$$

Tank/Vessel Overflow Line Sizing

DEVICE : Tank #2501; Overflow Tag: 03000

..... Vessel Fluid
Vessel Inflow: 78.358024 m ³ /hr	Liquid: WATER
W: 21.766118 kg/sec	Specific Gravity: 1.000
Δ P: 0.1016 meter	Density: 1000 kg/cu. meter
or 996.35564 Pa	Frictional Loss, N: 1.5 (simple overflow)

Select Overflow Pipe Schedule : Schedule 40 ▾

$$\text{dia} := \left[\left(808 \cdot 10^{-3} \right) \cdot N \cdot \frac{W^2}{(\Delta P \cdot D)} \right]^{0.25} = 154.93964 \text{ mm}$$

-- A 200 mm overflow is recommended --

..... **Selected Overflow Capacity**

DEVICE : Tank #2501; Overflow Tag: 03000

sp.gr. = 1.000	
ΔP= 0.1016 meter = 0.9962896 kPa	
D = 1.000 × 1000 = 1000 kg/cu. meter	
N = 1.5 (for simple o'flow)	
d = 202.74 millimeter (overflow ID)	

$$W := \sqrt{\left[\frac{\Delta P \cdot D \cdot d^4}{N \cdot (808 \cdot 10^{-3})} \right]} = 37.266652 \text{ kg/sec or } 134.2 \text{ cu. meter/hr}$$

LIQUID	sp. gr.	Overflow Selection Information						
		Case	Selection	Test	- A 30-inch overflow is recommended -			
ACETIC ACID 100%	1.050	Schedule 10	Schedule 40	1				
ACETIC ACID 70%	1.010	Schedule 10	Schedule 40	1				
ACETONE	0.789	Schedule 40						
AMINE OXIDE	0.950	Piping	Schedule 10 Lookup Table			Schedule 40 Lookup Table		
AMMONIA 26%	0.905	Size	schd 10S	next nom	next i.d.	nominal	schd 40	next nom
AMMONIA 100%	0.682	1/2	0.001	1/2	0.674	0.001	1/2	0.622
BENZENE 26%	0.844	1/2	0.674	3/4	0.884	0.622	3/4	0.824
BLACK LIQUOR 50%	1.250	3/4	0.884	1	1.097	0.824	1	1.049
BLACK LIQUOR 63%	1.330	1	1.097	1 1/4	1.422	1.049	1 1/4	1.38
BLACK LIQUOR 68%	1.360	1 1/4	1.422	1 1/2	1.682	1.380	1 1/2	1.61
BRINE, CALCIUM CHLORIDE 25%	1.230	1 1/2	1.682	2	2.157	1.610	2	2.067
BRINE, SODIUM CHLORIDE 25%	1.190	2	2.157	2 1/2	2.635	2.067	2 1/2	2.469
CARBON DIOXIDE	1.102	2 1/2	2.635	3	3.26	2.469	3	3.068
CAUSTIC 20%	1.223	3	3.260	3 1/2	3.76	3.068	3 1/2	3.548
CAUSTIC 50%	1.530	3 1/2	3.760	4	4.26	3.548	4	4.026
CHLORINE LIQUID	1.467	4	4.260	6	6.357	4.026	6	6.065
DOWTHERM A	0.995	6	6.357	8	8.329	6.065	8	7.981
ETHANOL 100%	0.789	8	8.329	10	10.42	7.981	10	10.02
ETHANOL 40%	0.935	10	10.420	12	12.39	10.020	12	11.938
ETHANOL 95%	0.804	12	12.390	14	13.624	11.938	14	13.25
ETHYL CHLORIDE	0.923	14	13.624	16	15.624	13.250	16	15.25
ETHYLENE GLYCOL	1.110	16	15.624	18	17.624	15.250	18	17.25
FREON, R11	1.410	18	17.624	20	19.564	17.250	20	19.25
FREON, R12	1.170	20	19.564	22	21.564	19.250	22	21.25
FREON, R22	1.440	22	21.564	24	23.5	21.250	24	23.25
FUEL OIL #2	0.876	24	23.500	26	25.376	23.250	26	25.25
FUEL OIL #6	0.993	26	25.376	28	27.376	25.250	28	27.25
GASOLINE	0.751	28	27.376	30	29.376	27.250	30	29.25
GLYCEROL, 100%	1.260	30	29.376	32	31.376	29.250	32	31.25
HYDROCHLORIC 31.5%	1.159	32	31.376	34	33.312	31.250	34	33.25
ISOPROPYL ALCOHOL	0.785	34	33.312	36	35.376	33.250	36	35.25
KEROSENE	0.811	36	35.376			35.250	36+	
LUBE OIL MOBIL 634	0.884							
METHANOL 100%	0.796							
METHANOL 40%	0.937							
METHANOL 90%	0.824							
METHYL CHLORIDE	0.998							
MULTITHERM PG-1	0.875							
NITRIC ACID 60%	1.370							
NITRIC ACID 95%	1.500							
OIL, VEGETABLE HARDENED	0.920							
OIL, VEGETABLE UNHARDENED	0.880							
SULPHUR DIOXIDE	1.434							
SULPHURIC 110%, FUMING	1.840							
SULPHURIC ACID 60%	1.500							
SULPHURIC ACID 98%	1.830							
TOLUENE	0.862							
TURPENTINE	0.864							
WATER	1.000							