



About this document

This document contains screenshots of software available from Cheresources.com. You can find this title in our online store at:

<http://www.cheresources.com/cheplusstore/catalogue.php>

Clicking the above link should activate your default browser and launch the site.

We recommend using our search feature to find the title.

If you haven't visited our site before, you can find the main page at:

<http://www.cheresources.com>

Thanks for visiting our site,

Chris Haslego
President
Cheresources, Inc.

© COPYRIGHT, 2005. CHERESOURCES, INC.

1422 Goswick Ridge Road
Midlothian VA 23114

Fax: 561-658-6489
Email: support@cheresources.com

**Content Based
Chemical Engineering**

FAILURE RATE - RELIABILITY - FAILURE PROBABILITY
risk assessment of components and systems

BASIS: CHEMICAL PROCESS SAFETY, FUNDAMENTALS with APPLICATIONS, by Daniel A. Crowl & Joseph F. Louvar; ISBN 0-13-129701-5

NOTE: Always begin a new case by retrieving the original file. Direct entry of data in cells that originally contain table lookups could cause functions to be lost, or incorrect calculations. I format cells requiring entry colored RED; calculated values are black.

- 1.) Enter the system, reference for calculation at [C5].
- 2.) Enter up to (6) components in parallel or series configuration at [B9:B14] or [B20:B25]. For components not listed in the lookup table [A48:A131] enter the name and its failure rate μ .
- 3.) The "combined" parallel or series failure rate, reliability, failure probability, and mean time between failures for each category are calculated and shown at row 15 for parallel and row 26 for series components.
- 4.) The combined unrevealed failure rate is shown at C29.
- 5.) Enter any "downtime" for inspections, calibration etc. at [C30]. Eight hours per year would be entered as =8/2080 the corresponding average unavailability and availability are shown at [C32] and [G32].
- 6.) The (MTBC) Mean Time Between Coincidence; unavailability during a process upset can be calculated by inputting the rate of process episodes Pd at [C37]. And the time interval (year) at [C38]. Using the previously determined unavailability the MTBC is shown at [D45].

NOTE: TO USE FOR COMBINED SYSTEMS, eg. two Parallel groupings in series with each other determine the parallel result, enter the totals for each in the Series section, then utilize the resulting total.

Print out using direct Excel commands. This application is provided by Chemical Engineers Resource Website, visit @cheresources.com for additional selections.

Print out using direct EXCEL commands.

<<<<<< Psafety © January 2001, by Don Coffman >>>>>>

The originator of these spreadsheet(s) specifically excludes all warranties, expressed or implied, as to the accuracy of the data and other information set forth and assumes NO liability for any losses or damage resulting from the use of the materials or application of the data. CONSISTENT WITH GOOD ENGINEERING PRACTICE, the burden rests with the USER of these spreadsheets to review ALL calculations, and assumptions. The USER IS FULLY RESPONSIBLE for the results or decisions based on calculations. This spreadsheet requires MACROS to be ENABLED to ASSURE proper operation. See the Workbook Help Sheet for Additional Instructions on Use.

dmcoffman@aol.com

Failure Rate - Reliability - Failure Probability
risk assessment of components and systems

SYSTEM: Example

parallel		failures/yr.	reliability	failure probability	mean time between failures
component		μ	$R = e^{-mt}$	$P = 1 - R$	MTBF
1:	pressure switch	0.1400	0.869	0.13064	7.14
2:	solenoid valve	0.4200	0.657	0.34295	2.38
3:		0.0000			
4:		0.0000			
5:		0.0000			
6:		0.0000			
total		0.0458	0.955	0.04480	21.82

series		failures/yr.	reliability	failure probability	mean time between failures
component		μ	$R = e^{-mt}$	$P = 1 - R$	MTBF
1:	pressure switch	0.1400	0.869	0.131	7.14
2:	indicator lamp	0.0440	0.957	0.043	22.73
3:		0.0000			
4:		0.0000			
5:		0.0000			
6:		0.0000			
total		0.184	0.832	0.168	5.43

unrevealed failures

$$\begin{aligned} \mu &= 0.230 \text{ faults/yr} \\ &= 0.083 \text{ yr (insp period, } 0.083 = 1/\text{month)} \end{aligned}$$

$$U = 0.5 * \mu * \tau_i = 0.0095 \text{ unavailability} \quad A = 1 - U = 99.046\% \text{ availability}$$

Mean time between coincidence (MTBC)

$$\begin{aligned} P_d &= 2.000 \text{ rate of process episodes} \\ T_i &= 1.000 \text{ time interval (yr)} \end{aligned}$$

$$\lambda = P_d / T_i = 2.000 \text{ process episode frequency}$$

$$\lambda_d = \lambda * U = 0.01908 \text{ avg freq of dangerous coincidences}$$

$$MTBC := \frac{1}{\lambda_d} = 52.420 \text{ years}$$

component	faults/yr
annunciators	0.00647
battery chargers	0.06384
batteries, lead acid	0.0189
batteries, nickel cadmium	0.00211
circuit breakers - AC	0.0147
circuit breakers - DC	0.03192
compressor	12.012
compressor (elec. driver)	20.748
computational module (pneu)	0.16296
controller	0.29
controller elec single loop	1.722
control valve	0.6
conveyor (screw)	7.9128
fan (motor driven)	0.07636
fire detection system	0.00958
fire suppression sys. (dry)	0.01184
fire suppression sys. (wet)	0.08114
flame detector	3.6288
flow measure (fluids)	1.14
flow measure (solids)	3.75
flow switch	1.12
fuses	0.00533
gas - liq chromatograph	30.6
generator, emergency diesel	18.9
hand valve	0.13
heat exchanger (shell&tube)	0.26124
hose (flexible)	0.00479
indicator lamp	0.044
indicator temperature	2.0832
inverters	0.24108
level measure (liquids)	1.7
level measure (solids)	6.86
motors, AC	0.12768
motors, AC induction	0.02688
motors, DC	0.189
oxygen analyzer	5.65
pH meter	5.88
pipe connection (metal)	0.00479
pipe (plastic)	0.00743
pipe (lined)	0.00371
pipe (metal)	0.00023
pressure measurement	1.41
pressure relief valve	0.022
pressure switch	0.14
pump (motor driven-cent.)	2.4528
pump (turbine driven)	0.74844
recorders	0.21084
relays, protective	0.01604
safety valve (spring-type)	0.01411
solenoid valve	0.42
stepper motor	0.044
strip chart recorder	0.22
switches elec flow	0.22512
switches elec level	0.01462
switches elec pressure	0.41664
switches elec temperature	0.02856
switches elec speed	0.00403
switches pneu/flow	0.0336
switches pneu/level	0.00521
switches pneu/pressure	0.04368
switches pneu/temperature	0.042
thermocouple temp. measu	0.52
thermometer temp. measu	0.027
transducer-current to pneu	0.52752
transformer, power	0.02125
transformer, rectifier	0.00899
trans elec capacitance prot	0.21084
transmitter delta pressure	1.8312
trans. pneu flow eP	0.9912
trans. pneu flow vari. area	0.80892
transmitter pneu level eP	0.83496
transmitter pne level float	1.5708
transmitter pneu pressure	0.76692
transmitter temperature	0.8148
valve (manual check)	0.02671
valve (manual hand)	0.00128
valve (motor operated)	0.01142
valve (pneumatic operated)	0.03016
valve positioner	0.44
valve (solenoid operated)	0.40908
vessel (atmos metallic)	0.00827
vessel (atmos non-metallic)	0.01016
vessel (pressure-metallic)	9.2E-05