



### **About this document**

This document contains screenshots of software available from Cheresources.com. You can find this title in our online store at:

<http://www.cheresources.com/cheplusstore/catalogue.php>

Clicking the above link should activate your default browser and launch the site.

We recommend using our search feature to find the title.

If you haven't visited our site before, you can find the main page at:

<http://www.cheresources.com>

Thanks for visiting our site,

Chris Haslego  
President  
Cheresources, Inc.

**© COPYRIGHT, 2005. CHERESOURCES, INC.**

1422 Goswick Ridge Road  
Midlothian VA 23114

Fax: 561-658-6489  
Email: [support@cheresources.com](mailto:support@cheresources.com)

***Content Based  
Chemical Engineering***

Vent Sizing For Vessels
-------------------------

**NOTE:** Always begin a new case by retrieving the original file. Direct entry of data in cells that originally contain table lookups could cause functions to be lost, or incorrect calculations. I format cells requiring entry colored **RED**; calculated values are black.

- Steam Condensing on Tank Surfaces

**BASIS:** Necessary air inflow through the vent must be sufficient to replace the volume of steam condensed within the tank.

**This spreadsheet covers three cases:**

- Case A:** - Cylindrical Tank, Steam Condensing on Roof and Shell
- Case B:** - Cylindrical Tank, Steam Condensing on Roof, Shell, and Bottom
- Case C:** - General Case, Steam Condensing on Tank Surface

- 1.) Enter the identification at [C4].
- 2.) Use the drop-box to select the case, A, B, or C.
- 3.) Enter tank MAV at [D7].
- 4.) For Cases A and B: enter height at [D8] and diameter at [D9]. For Case C: enter total condensing area at [D14].  
The required vent area is indicated at C25, add this to any other venting requirements. Note that this area is valid for 'natural' reliefs only (short nozzles). For long or complex vents, eg. with a vapor seals the required air inflow rate for this hazard is shown at F31. This rate can be used with the DARCY spreadsheets to determine appropriate piping size, etc...

- Cold Water Spray - Steam Condensing

**BASIS:** This spreadsheet allows for input of a varying degrees of minimum water temperatures used for rinsing tanks such as used in CIP operations. Venting considerations of a "cold summer" rain shower on exterior surfaces are also a consideration of needed air inflow.

- 1.) Enter the identification at [C4].
- 2.) Enter tank MAV at [C6].
- 3.) Enter the MINIMUM POSSIBLE water temperature at [F6] (consider winter water temperatures).
- 4.) Enter water mass spray rate at [F7] the equivalent volumetric rate is reflected at [F8].  
The required vent area is indicated at E18, add this to any other venting requirements. Note that this area is valid for 'natural' reliefs (short nozzles) only. For long or complex vents, eg. with a vapor seals the required air inflow rate for this hazard is shown at F26. This rate can be used with the Darcy spreadsheet to determine appropriate piping size, etc...

- Vacuum Hazard from Draindown & Pumpout

**BASIS:** Drain valves are calculated as liquid orifices, the vent area is calculated using the an orifice coefficient of 0.60 (equivalent of a short nozzle).

- 1.) Enter identification at [C4].
- 2.) Enter MAV at [C6].
- 3.) Enter tank maximum liquid height at [C7].
- 4.) Enter fluid at [G6].
- 5.) Enter specific gravity at [G7].
- 6.) Enter drain valve "Ko" at [G11] if different from 0.8.
- 7.) Enter the inside diameter for each drain at [D14]...[D18] (see piping table).
- 8.) Enter pump names/reference at [C24]...[C28] and their maximum flows [G24]...[G28].  
The required vent area is indicated at F38, add this to any other venting requirements. Note that this area is valid for 'natural' reliefs (short nozzles) only. For long or complex vents, eg. with a vapor seals the required air inflow rate for this hazard is shown at F47. This rate can be used with the Darcy spreadsheet to determine appropriate piping size, etc...

- Tank Venting for Gas & Liquid Inflows

**BASIS:** The program sizes a natural relief for gas inflow, plus the gas displaced by liquid inflows; NOT for combined gas/liquid flow through the vent. An adequate overflow is assumed.

- 1.) Enter identification at [C4].
- 2.) Enter MAP at [C6].
- 3.) Enter allowable overpressure at [F6].
- 4.) Enter gas name at [C14], or " = " and schroll down to the appropriate gas in the lookup table starting at cell [E49].
- 5.) Enter the mass flow rate, at [C15]. The molecular weight (mw), specific heat ratio (k), are automatically added from the lookup table, if the fluid was listed.
- 6.) Input the temperature at [C16]. If the fluid is steam the spreadsheet will determine temperature. The specific volume will be calculated and shown at [G15].
- 7.) Enter Ko at [G10], use the Comment Box info to select Ko.
- 8.) Enter liquid name at [C24], or " = " and schroll down to the appropriate liquid in the lookup table starting at cell [A49].
- 9.) Enter the mass flow rate at [C25] the volumetric rate is calculated and reflected at [C26]. The specific gravity is automatically added from the lookup table, if the fluid was listed. The volumetric flow is calculated and shown at [F18].

**NOTE:** The gas displaced by liquid is calculated and shown at [E30], and the total vent flow at [E35]. This total flow may be used with DARCY for complex or piped vent arrangements. The required vent area shows at [F39], and its diameter at [G41]. A recommended vent size based on schd 40 pipe is shown at [C44].

**Print out using direct Excel commands. This application is provided by Chemical Engineers Resource Website, visit [cheresources.com](http://cheresources.com) for additional selections.**

**Print out using direct EXCEL commands.**

<<<<<<<< Psafety © January 2001, by Don Coffman >>>>>>>>

The originator of these spreadsheet(s) specifically excludes all warranties, expressed or implied, as to the accuracy of the data and other information set forth and assumes NO liability for any losses or damage resulting from the use of the materials or application of the data.

Consistent with GOOD ENGINEERING PRACTICE, the burden rests with the USER of these spreadsheets to review ALL calculations, and assumptions. The USER IS FULLY RESPONSIBLE for the results or decisions based on calculations.

This Spreadsheet Requires MACROS to be ENABLED to ASSURE proper operation. See the Workbook Help Sheet for Additional Instructions on Use.

dmcoffman@aol.com

Tank Vent Requirement - Steam Condensation on Tank Surface
--

**TANK:** Hot Water Vessel, VE-8002

**CASE:** Steam Condensing on Roof, Shell, and Bottom

MAV = 3.000 psi  
 Height = 132.0 inches or 11.00 ft.  
 Diameter = 96.0 inches or 8.00 ft.

Ab = 50 ft<sup>2</sup> bottom area assumed flat  
 Ar = 50 ft<sup>2</sup> roof area assumed flat  
 As = 276 ft<sup>2</sup> shell surface area  
 Acond = 377 ft<sup>2</sup> total condensing area

..... vent sizing .....

P1a = 14.7 psia                      P2a/P1a = 0.796  
 P2a = 11.7 psia                      lambda = 965 for Air  
    for (P2a/P1a < .975)

$$d = 2.8 \cdot (A_{\text{cond}}/\lambda)^{0.5}$$

$$d = 1.75 \text{ in.}$$

$$A_v = 2.404799 \text{ in}^2 \text{ required vent area}$$

..... required air inflow .....

$$W := K_o \cdot A \cdot \lambda \cdot \sqrt{\left(\frac{P1_a}{V_1}\right)} = 1463 \text{ lb/hr}$$

Tank Vent Requirement - Steam Condensation on Tank Surface
--

**TANK:** Hot Water Vessel, VE-8002**CASE:** Steam Condensing on Roof and Shell

MAV = 20684 Pa  
 Height = 3352.8 millimeter or 3.3528 meter  
 Diameter = 2438.4 millimeter or 2.4384 meter

Ar = 4.67 meter<sup>2</sup> roof area assumed flat  
 As = 25.68 meter<sup>2</sup> shell surface area  
 Acond = 30.35 meter<sup>2</sup> total condensing area

..... vent sizing .....

P1a = 101325 Pa.abs                  P2a/P1a = 0.796  
 P2a = 80641 Pa.abs                lambda = 965 for Air  
     for (P2a/P1a < .975)

$$d = 0.233 \cdot (A_{\text{cond}}/\lambda)^{0.5}$$

$$d = 41.315379 \text{ millimeter}$$

$$A_v = 1340.644 \text{ millimeter}^2 \text{ required vent area}$$

..... required air inflow .....

$$W := 5.88 \cdot K_o \cdot A \cdot \lambda \cdot \sqrt{\frac{P1_a}{V_1}} \cdot 10^{-4} = 0.1593 \text{ kg/sec}$$

## Tank Vent Requirement - Cold Water Spray

**TANK:** Final Mix Tank - HAZARD 7

$$\begin{aligned} \text{MAV} &= 0.87 \text{ psig} \\ &= 13.826 \text{ psia} \\ \text{Tsatsat} &= 209.2398 \text{ }^\circ\text{F} \end{aligned}$$

$$\begin{aligned} T_w &= 48 \text{ }^\circ\text{F, minimum cold temp} \\ W &= 15000 \text{ lb/hr, spray rate} \\ Q &= 30.00 \text{ gpm, spray rate} \\ \Delta T &= 161.23984 \text{ }^\circ\text{F, temp differential} \end{aligned}$$

..... vent sizing .....

$$\begin{aligned} P_{1a} &= 14.7 \text{ psia} \\ P_{2a} &= 13.83 \text{ psia} \\ P_{2a}/P_{1a} &= 0.941 \\ \lambda &= 569 \end{aligned}$$

$$A := \left( \frac{0.002439 \cdot \Delta T \cdot W}{\lambda} \right) = 10.371977 \text{ in}^2 \text{ required vent area}$$

$$\text{this area} = 3.634 \text{ in. diameter}$$

..... required air inflow .....

$$W := K_o \cdot A \cdot \lambda \cdot \sqrt{\left( \frac{P_{1a}}{V_1} \right)} = 3716.5419 \text{ lb/hr}$$

## Tank Vent Requirement - Cold Water Spray

**TANK:** Final Mix Tank - HAZARD 7

MAV = 5998.4 Pa	Tw = 8.89 °C, minimum cold temp
= 95326.6 Pa..abs	W = 1.890 kg/sec, spray rate
Tsat = 100.5722 °C	Q = 6.80 m <sup>3</sup> /hr, spray rate
	ΔT = 91.68 °C, temp differential

..... vent sizing .....

P1a = 101325 Pa..abs
P2a = 95326.561 Pa..abs
P2a/P1a = 0.941
λ = 569

$$A := \left( \frac{0.0225 \cdot \Delta T \cdot W}{\lambda} \right) = 6854.4438 \text{ mm}^2 \text{ required vent area}$$

this area = 93.420 mm diameter

..... required air inflow .....

$$W := 5.88 \cdot K_o \cdot A \cdot \lambda \cdot \sqrt{\frac{P1_a}{V_1}} \cdot 10^{-4} = 0.4798993 \text{ kg/sec}$$

Vacuum Hazard - From Drain Down and Pump Out

**VESSEL :** Brine Tank; 50-D-90226

MAV:	0.2	psi	Fluid:	BRINE, CALCIUM CHLORIDE 25%
Liquid Height:	100	inches or 8.33 feet	Sp Gr:	1.230 specific gravity
Liquid Head:	4.437	psi, liquid	Density:	76.752 lb/cu ft

..... for drains .....

Ko = 0.8

$$W := 2410 \cdot K_o \cdot A \cdot \sqrt{(P_1 - P_2) \cdot D}$$

drain #1:	1.610	in.Ø	-----	W <sub>1</sub> :	72435.165	lb/hr
drain #2:	0.000	in.Ø	-----	W <sub>2</sub> :	0	lb/hr
drain #3:	0	in.Ø	-----	W <sub>3</sub> :	0	lb/hr
drain #4:	0	in.Ø	-----	W <sub>4</sub> :	0	lb/hr
drain #5:	0	in.Ø	-----	W <sub>5</sub> :	0	lb/hr
					72435.165	total lb/hr

**SUB TOTAL - DRAINS :** 117.8 gpm, drains

..... for pumps .....

pump #1:	Brine Regeneration Pump	-----	Q <sub>1</sub> :	100	gpm
pump #2:		-----	Q <sub>2</sub> :	0	gpm
pump #3:		-----	Q <sub>3</sub> :	0	gpm
pump #4:		-----	Q <sub>4</sub> :	0	gpm
pump #5:		-----	Q <sub>5</sub> :	0	gpm

**SUB TOTAL - PUMPS :** 100 gpm, pumps

**TOTAL OUTFLOW :** 217.78076 gpm

..... required vent area to relieve draindown/pumpout

Ko = 0.6

$$A := \text{GPM} \cdot 0.075 \cdot \left[ \frac{60}{7.48 \cdot \left[ \frac{2410}{\left( \frac{K_o}{\sqrt{\text{MAV} \cdot 0.075}} \right)} \right]} \right] = 0.740 \text{ in}^2$$

or, Ø = 0.971 inch diameter

..... required air inflow .....

$$W := K_o \cdot A \cdot \lambda \cdot \sqrt{\left( \frac{P_1}{V_1} \right)} = 130.2351 \text{ lb/hr}$$

Vacuum Hazard - From Drain Down and Pump Out

**VESSEL :** Brine Tank; 50-D-90226

MAV: 1378.9515 Pa  
 Liquid Height: 2540 mm or 2.54 meter  
 Liquid Head: 30637.936 Pa, liquid

Fluid: BRINE, CALCIUM CHLORIDE 25%  
 Sp Gr: 1.230 specific gravity  
 Density: 1230 kg/cu meter

..... for drains .....

Ko = 0.8

$$W := 1.42 \cdot K_o \cdot A \cdot \sqrt{(P_1 - P_2)} \cdot D$$

drain #1:	40.94	- mmØ -----	W <sub>1</sub> :	9.180	kg/sec
drain #2:	0	- mmØ -----	W <sub>2</sub> :	0.000	kg/sec
drain #3:	0	- mmØ -----	W <sub>3</sub> :	0.000	kg/sec
drain #4:	0	- mmØ -----	W <sub>4</sub> :	0.000	kg/sec
drain #5:	0	- mmØ -----	W <sub>5</sub> :	0.000	kg/sec
				9.1800743	total kg/sec

**SUB TOTAL - DRAINS :** 26.86851 m<sup>3</sup>/hr, drains

..... for pumps .....

pump #1: Brine Regeneration Pump	-----	Q <sub>1</sub> :	22.712471	m <sup>3</sup> /hr
pump #2:	-----	Q <sub>2</sub> :	0	m <sup>3</sup> /hr
pump #3:	-----	Q <sub>3</sub> :	0	m <sup>3</sup> /hr
pump #4:	-----	Q <sub>4</sub> :	0	m <sup>3</sup> /hr
pump #5:	-----	Q <sub>5</sub> :	0	m <sup>3</sup> /hr

**SUB TOTAL - PUMPS :** 22.712471 m<sup>3</sup>/hr, pumps

**TOTAL OUTFLOW :** 49.580981 m<sup>3</sup>/hr

..... required vent area to relieve draindown/pumpout

Ko = 0.6

$$A := \frac{m^3}{hr} \cdot 1.20 \cdot 1000 \cdot \left[ \frac{1000}{3600} \cdot \left[ \frac{1.42}{K_o} \cdot \left( \frac{1}{\sqrt{MAV \cdot 1.20}} \right) \right] \right] = 476.858 \text{ mm}^2$$

or, Ø = 24.641 mm diameter

..... required air inflow .....

$$W := 5.88 \cdot K_o \cdot A \cdot \lambda \cdot \sqrt{\frac{P1_a}{V_1}} \cdot 10^{-4} = 0.0164061 \text{ kg/sec}$$



## Tank Venting Requirements For Gas and Liquid Inflows

### SERVICE: 50% CAUSTIC STORAGE TANK VENTING FROM AIR BLOW

MAP = 1.00	psig	% OP = 10.0	over pressure
P1 = 1.100	psig	P1a = 15.800	psia
P2 = 0.000	psig	P2a = 14.696	psia
		Ko = 0.8	

#### ..... compressible inflow .....

Fluid: STEAM			
Mass Flow Rate:	14675	W, lb/hr	v1 = 14.41 cu ft/lb
	T1: 246.85	°F	T1a = 706.4462 °R
Ratio of Sp. Ht.:	1.32	k	PRcrit = 0.5430
MW:	18.02	molecular wt.	λ = 612
PR:	0.9301	pressure ratio	crit λ = 1144

#### ..... noncompressible inflow .....

Fluid: WATER			
Mass Flow Rate:	25083	W, lb/hr	Sp. Gr.: 1.00 specific gravity
Volumetric Rate:	50.2	Q, gpm	Density: 62.40 lb/cu ft

$$W_L := \left( \frac{Q}{7.48} \right) \left( \frac{60}{v_1} \right) = 27.932848 \text{ lb/hr, gas displaced}$$

#### ..... required area .....

$$W_{\text{tot}} = W_g + W_L = 14703 \text{ lb/hr, total required vent flow}$$

$$A := \frac{W_{\text{tot}}}{K_o \cdot \lambda \cdot \sqrt{\left( \frac{P1_a}{v_1} \right)}} = 28.65 \text{ in}^2$$

or 6.040 inch inside diameter

**Use a 6 inch Schedule 40 or Equivalent Size Vent.**

## Tank Venting Requirements For Gas and Liquid Inflows

### SERVICE: 50% CAUSTIC STORAGE TANK VENTING FROM AIR BLOW

MAP = 6894.76 Pa	% OP = 10.0 over pressure
P1 = 7584.233 Pa	P1a = 108909.23 Pa..abs
P2 = 0.000 Pa	P2a = 101325 Pa..abs
Ko = 0.8	

#### ..... compressible inflow .....

Fluid: STEAM		
Mass Flow Rate: 1.8490189 W, kg/sec		v1 = 0.90 m <sup>3</sup> /kg
T1: 119.36 °C		T1a = 392.509 °K
Ratio of Sp. Ht.: 1.32 k		PRcrit = 0.5430
MW: 18.02 molecular wt.		λ = 612
PR: 0.9304 pressure ratio		crit λ = 1144

#### ..... noncompressible inflow .....

Fluid: WATER		
Mass Flow Rate: 3.1604048 W, kg/sec		Sp. Gr.: 1.00 specific gravity
Volumetric Rate: 11.377457 Q, m <sup>3</sup> /hr		Density: 1000.00 kg/m <sup>3</sup>

$$W_L := 1.29 \cdot \left( \frac{Q}{3600} \right) = 0.0040769 \text{ kg/sec, gas displaced}$$

#### ..... required area .....

$$W_{\text{tot}} = W_g + W_L = 1.8530958 \text{ kg/sec, total required vent flow}$$

$$A := \frac{(W_{\text{tot}} \cdot 10^4)}{5.88 \cdot K_o \cdot \lambda \cdot \sqrt{\left( \frac{P1_a}{v_1} \right)}} = 18511.31 \text{ mm}^2$$

or 153.52 mm inside diameter

**Use a 150 mm Schedule 40 or Equivalent Size Vent.**

FLUID PROPERTIES			GAS PROPERTIES				ASME Steam Table - 1967 (Keenan & Keyes)			
liquid	spec. grav	gas	chem	sp.ht. ratio	mw	Applicable from 0 - 850 psig		Imperial	Metric	
ACETIC ACID 100%	1.050	ACETIC ACID	CH3COOH	1.30	60.05	Pressure, gauge : psi   Pa		13.83	95326.9	
ACETIC ACID 70%	1.010	ACETYLENE	C2H2	1.30	26.00	Pressure, abs : psi   Pa		28.52	196651.9	
ACETONE	0.789	AIR		1.40	28.97	Temperature : °F   °C		246.85	119.4	
AMMONIA 26%	0.905	AMMONIA	NH3	1.30	17.030	Temperature, abs : °R   °K		706.52	392.5	
AMMONIA 100%	0.682	ARGON	A	1.40	39.90	Steam Enthalpy : btu/lb kJ/kg		1162.9	4868.8	
BENZENE	0.844	BENZENE	C6H6	1.30	78.11	Water Enthalpy : btu/lb kJ/kg		215.4	901.8	
BRINE, CALCIUM CHLORIDE 25%	1.230	BROMINE	Br2	1.30	159.83	Evap Enthalpy : btu/lb kJ/kg		947.5	3967.0	
BRINE, SODIUM CHLORIDE 25%	1.190	BUTANE	C4H10	1.30	58.10	Steam Specific Volume : ft³/lb m³/kg		14.4060	0.8993	
CARBON DIOXIDE	1.102	CARBON DIOXIDE	CO2	1.30	44.010	Steam Density : lb/ft³ kg/m³		0.0694	1.1119	
CAUSTIC 20%	1.223	CARBON DIOXIDE	CS2	1.30	76.13	Water Density : lb/ft³ kg/m³		58.875	943.080	
CAUSTIC 50%	1.530	CARBON MONOXIDE	CO	1.40	28.010	Water Specific Volume : ft³/lb m³/kg		0.01699	0.00106	
CHLORINE LIQUID	1.467	CHLORINE	CL2	1.30	70.910	Ratio of Spec Heat : Cp/Cv		1.315	1.315	
CONDENSATE	1.000	CHLOROFORM	CHCl3	1.30	119.39	Pipe Size LookUp Table				
DOWTHERM A	0.995	CYANOGEN	(CN)2	1.30	52.02	nom dia	ID sch 40	next ID		
ETHANOL 100%	0.789	CYCLOHEXANE	C6H12	1.30	84.16		0.001	3/4		
ETHANOL 40%	0.935	ETHANE	C2H6	1.30	30.00	1/2	0.622	3/4		
ETHANOL 95%	0.804	ETHYL ALCOHOL	C2H5OH	1.30	46.07	3/4	0.824	1		
ETHYL CHLORIDE	0.923	ETHYL CHLORIDE	C2H5CL	1.30	64.50	1	1.049	1 1/4		
ETHYLENE GLYCOL	1.110	ETHYLENE GLYCOL	(C2H5)2O	1.30	74.12	1 1/4	1.38	1 1/2		
FREON, R11	1.410	ETHYLENE	C2H4	1.30	28.000	1 1/2	1.61	2		
FREON, R12	1.170	FREON 11	F-11	1.30	137.40	2	2.067	2 1/2		
FREON, R22	1.440	FREON 114	F-114a	1.30	170.90	2 1/2	2.469	3		
FUEL OIL #2	0.876	FREON 12	R-12	1.30	120.93	3	3.068	3 1/2		
FUEL OIL #6	0.993	FREON 22	R-22	1.30	86.48	3 1/2	3.548	4		
GASOLINE	0.751	FREON HF	CH2FCF3	1.30	102.03	4	4.026	6		
GLYCEROL, 100%	1.260	FUEL OIL (#2)		1.30	96.00	6	6.065	8		
HYDROCHLORIC 31.5%	1.159	GASOLINE		1.30	86.00	8	7.981	10		
ISOPROPYL ALCOHOL	0.785	HELIUM	He	1.40	4.00	10	10.02	12		
KEROSENE	0.811	HEPTANE	C7H16	1.30	100.20	12	11.938	14		
LUBE OIL MOBIL 634	0.884	HEXANE	C6H14	1.30	86.17	14	13.124	16		
METHANOL 100%	0.796	HYDROCHLORIC	HCl	1.40	36.47	16	15	18		
METHANOL 40%	0.937	HYDROGEN	H2	1.40	2.02	18	16.867	20		
METHANOL 90%	0.824	HYDROGEN	HBr	1.40	80.92	20	18.812	22		
METHYL CHLORIDE	0.998	HYDROGEN	HCl	1.40	36.47	22	21.25	24		
MULTITHERM PG-1	0.875	HYDROGEN	HCN	1.30	27.03	24	23.25	26		
NITRIC ACID 60%	1.370	HYDROGEN	HI	1.40	127.91	26	25.25	28		
NITRIC ACID 95%	1.500	HYDROGEN	H2S	1.30	34.08	28	27.25	30		
OIL, VEGETABLE HARDENED	0.920	IODINE	I2	1.30	253.84	30	29.25	32		
OIL, VEGETABLE UNHARDENED	0.880	ISOBUTANE	C4H10	1.30	58.10	32	31.25	34		
SULPHUR DIOXIDE	1.434	ISOPENTANE	C5H12	1.30	72.10	34	33.25	36		
SULPHURIC 110%, FUMING	1.840	MERCURY	Hg	1.40	200.60	36	35.25	VERY BIG		
SULPHURIC ACID 60%	1.500	METHANE	CH4	1.30	16.040					
SULPHURIC ACID 98%	1.830	METHYL ALCOHOL	CH3COOH	1.30	74.08					
TOLUENE	0.862	METHYL ALCOHOL	CH3OH	1.30	32.04					
TURPENTINE	0.864	METHYL CHLORIDE	CH3Cl	1.30	50.49					
WATER	1.000	METHYLENE CHLORIDE	(CH2)2O	1.30	46.07					
		NATURAL GAS	typical	1.30	19.50					
		NEON	Ne	1.40	20.20					
		NITRIC OXIDE	NO	1.40	30.010					
		NITROGEN	N2	1.40	28.020					
		NITROUS OXIDE	N2O	1.30	44.020					
		OCTANE	O2	1.30	114.22					
		OXYGEN	O2	1.40	32.000					
		PENTANE	C5H12	1.30	72.10					
		PHOSPHORUS	P	1.30	30.97					
		POTASSIUM	K	1.40	39.10					
		PROPANE	C3H8	1.30	44.10					
		PROPENE	C3H6	1.30	42.10					
		SODIUM	Na	1.40	22.99					
		STEAM	H2O	1.32	18.020					
		SULPHUR DIOXIDE	SO2	1.30	64.070					
		TOLUENE	C6H5CH3	1.30	92.13					