

# PRESENT SITUATION

Q (heat flow) required to be exchange: 1426 KW

Define from Hysys simulation with 60°C-7.3°C: 52.7 °C Temp. Differential and 24270 Kg/hr mass flowrate.

